

Name(s) of Risk Team Members: J. Scott, J. Scaduto			Point Value → Parameter ↓	1	2	3	4	5					
Area/Facility Description Title: Collider-Accelerator Area/Facility # (if applicable): Area-Wide FRA 14-05			Occupancy or Use	≤once/year	≤once/month	≤once/week	≤once/shift	>once/shift					
Area/Facility Description: PHOBOS Area-Wide			Severity	First Aid Only	Medical Treatment	Lost Time	Partial Disability	Death or Permanent Disability					
			Likelihood	Extremely Unlikely	Unlikely	Possible	Probable	Multiple					
Approved by: <i>E. Lessard</i> Date: 3-21-05 Rev.#: 0													
Reason for Revision (if applicable):						Comments:							
			Before Additional Controls						After Additional Controls				
Physical Item or Activity	Hazard(s)	Control(s)	Occupancy A	Severity B	Likelihood C	Risk* AxBxC	Control(s) Added to Reduce Risk		Occupancy A	Severity B	Likelihood C	Risk* AxBxC	% Risk Reduction
Primary Beam	High hazard ionizing radiation	ACS; PASS; postings; crash buttons and chords; C-AD area classification; shielding; dosimeters; training; RSC reviews, FS support, RWP	1	5	2	10							
General Area Radiation Residual Radiation, External Radiation	Ionizing radiation	Postings, training, shielding, RCD surveys, RCD oversight, RWP, work planning, procedures, dosimetry	4	1	2	8							
Electrical Equipment & Power Supplies BNL Class A & B <250 V AC; <1000V DC	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; disconnected cable policy; installations comply with applicable codes; procedures; training; distribution drawings; LOTO; Kirk keys; working hot permits; ASSRC/ESRC reviews; qualified electricians and technicians; cabinet interlocks; postings; locked areas; guarding; work planning; GFCI; grounding standards; emergency procedures	5	4	2	40	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.		5	3	2	30	25%
Electrical Equipment & Power Supplies BNL Class C <600 V AC; <6000 V DC	Arc blast; burn	Procedures, training, PPE, all equipment is listed or reviewed by CEE, tier 1 inspections, disconnected cable policy, installations comply with applicable codes, distribution drawings, LOTO, Kirk keys, working hot permits, work planning, GFCI, grounding standards, emergency procedures and emergency response, qualified electricians and technicians, cabinet interlocks, guarding and barriers, postings, locked areas.	3	5	2	30	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.		3	4	2	24	20%
Electrical Equipment & Power Supplies BNL Class C <600 V AC; <6000 V DC	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; disconnected cable policy; installations comply with applicable codes; procedures; training; distribution drawings; LOTO; Kirk keys; working hot permits; ASSRC/ESRC reviews; qualified electricians and technicians; cabinet interlocks; postings; locked areas; guarding; work planning; GFCI; grounding standards; emergency procedures; two-person rule for hot work, PPE	2	5	2	20	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.		2	4	2	16	20%

Electrical Disconnects And Switches	Arc blast; burn	Procedures, training, PPE(see controls above, all apply to this)	2	4	3	24	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.	2	3	3	18	25%
Electrical Disconnects And Switches	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; disconnected cable policy; installations comply with applicable codes; procedures; training; distribution drawings; LOTO; Kirk keys; working hot permits; qualified electricians and technicians; cabinet interlocks; postings; locked areas; guarding; work planning; GFCI; grounding standards; emergency procedures; two-person rule for hot work	2	5	2	20	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.	2	4	2	16	20%
Motor Control Centers; Panels And Wall Sockets	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; disconnected cable policy; installations comply with applicable codes; procedures; training; distribution drawings; LOTO; Kirk keys; working hot permits; ASSRC/ESRC reviews; qualified electricians and technicians; cabinet interlocks; postings; locked areas; guarding; work planning; grounding standards	4	5	2	40	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.	4	4	2	32	20%
Motor Control Centers; Panels And Wall Sockets	Arc blast; burn	PPE; training; procedures	4	4	2	32	BNL working towards compliance with NFPA 70E PPE, training, and posting requirements for all personnel, UL or equivalent approval of all equipment required or on site experts to approve it.	4	3	2	24	25%
Electrical Powered Hand Tools	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; procedures; training; labeling; work planning; GFCI; grounding standards; double insulation	4	3	3	36						
Extension Chords; Temporary Wiring And Power Strips	Shock or electrocution	All equipment is listed or reviewed by CEE; Tier 1 inspections; disconnected cable policy; installations comply with applicable codes; procedures; training; distribution drawings; qualified electricians and technicians; GFCI; grounding standards, proper uses understood.	4	3	3	36						
Vacuum	Ear damage	Postings; PPE; maintenance; training; work planning; ASSRC reviews; procedures; Tier 1 inspections; Chief ME reviews; vacuum windows covered during handling; use of industry standards; design reviews, LOTO, PPE	3	4	2	24						
Vacuum	Being struck by an object such as flying debris	Postings; PPE; maintenance; training; work planning; ASSRC reviews; procedures; Tier 1 inspections; Chief ME reviews; vacuum windows covered during handling; use of industry standards; design reviews, LOTO, PPE	3	4	2	24						
Magnetic Field	Being struck by an object due to adverse mechanical force exerted on ferromagnetic objects and or to electronic/medical implants	Barriers; warning systems; postings; training; ESRC review; work planning; procedures; Tier 1 inspections; magnetic safety reviews; medical exams	1	4	2	8						
Lighting	Being struck against an object, such as a carpenter walking into a door frame, due to poor visibility	Tier 1 inspections; maintenance; emergency lighting; temporary lighting, work planning, housekeeping policy.	3	2	3	18						
Lighting	Falls on same level	Tier 1 inspections; maintenance; emergency lighting; temporary lighting, work planning, housekeeping policy	3	3	3	27						
Lighting	Being struck by an object due to a material handling mishap	Tier 1 inspections; maintenance; emergency lighting; temporary lighting, work planning, housekeeping policy	2	3	3	18						

Material Handling	Being struck by an object due to improperly secured material; loss of control	Work planning; equipment specific training; work area barricades and controls; PPE; clamps; straps; vices; fixtures, equipment inspections, procedures.	3	3	3	27					
Chemical Handling	Eye exposure	Procedures; compliance with regulations; training; CMS inventory; MSDS; volume controls; PPE as required; locked or controlled areas; postings; labeling; proper containers; segregation; proper spill cleanup equipment available; Tier 1 inspections	3	4	2	24					
Chemicals	Inhalation exposure	Procedures; compliance with regulations; training; CMS inventory; MSDS; volume controls; PPE as required; locked or controlled areas; postings; labeling; proper containers; segregation; proper spill cleanup equipment available; Tier 1 inspections	3	3	2	18					
Chemicals	Fire; explosions	Procedures; compliance with regulations; training; CMS inventory; MSDS; volume controls; PPE as required; locked or controlled areas; postings; labeling; proper containers; segregation; proper spill cleanup equipment available; Tier 1 inspections	3	2	2	12					
Manual Material Handling	Overexertion – injuries caused by excessive lifting, pushing, pulling, holding, carrying or throwing of an object	Gloves; hardhat; handcarts; dollies; training; safety shoes, weight limits, work planning.	4	3	3	36					
Use Of Hand Tools	Being struck by an object, such as flying chips	PPE; training; maintenance; Tier 1 inspections; UL listed equipment; pre-inspections	4	2	3	24					
Use Of Hand Tools	Being struck against an object, such as sharp surfaces	PPE; training; guarding	4	2	3	24					
Use Of Hand Tools	Becoming caught in or compressed by equipment	Equipment specific training; guarding; PPE; postings	4	2	3	24					
Walking – Working Surfaces	Falls on same level	PPE; Tier 1; work planning; P.E. scheduled maintenance; internal and external audits; posting; labeling; training; barriers; communication; lessons learned, procedures, PPE(safety shoes, rubber spikes for winter use). Heightened awareness and repair of walking and working surfaces.	5	4	2	40					
Working Environment	Poor air quality; mold	HVAC; facility maintenance; Tier 1 inspections, housekeeping policy, IH sampling if required.	5	2	2	20					
Work At Heights	Falls to lower level, such as falling from a ladder or over a railing	Postings; barriers; fall protection; maintenance; training; work planning; procedures; Tier 1 inspections; PPE; approved scaffolding and platforms; approved ladders; anti-slip surfaces	2	5	3	30					
Water	Being struck by an object due to a pressure release	Postings; maintenance; PPE; training; work planning; ASSRC review; procedures; Tier 1 inspections; PLC monitoring and interlocks, LOTO, qualified personnel	4	1	3	12					
Water	Contact with temperature – extremes that result in such injuries as heat exhaustion, frost bite or burns	Postings; maintenance; PPE; training; work planning; ASSRC review; procedures; Tier 1 inspections	4	3	2	24					
Tours	Internal or external radiation	Postings; trained escorts; RCD concurrence to enter radiation areas; RWP; work planning; training waiver; red TLD; BNL minors policy	3	1	2	6					

[illegible]

*Risk:	0 to 20	21 to 40	41-60	61 to 80	81 or greater
	Negligible	Acceptable	Moderate	Substantial	Intolerable